

To: Restaino, Mark[restaino.mark@epa.gov]
From: Restaino, Mark
Sent: Tue 4/22/2014 1:51:38 AM
Subject: Izaty's Info

Steve Shumacher's phone number 320-532-4840.

From: Restaino, Mark
Sent: Monday, April 21, 2014 8:47 PM
To: 'sschumacher@izatys.com'
Cc: 'Scott Hansen'
Subject: Tank Information

Steve,

For more information regarding installing and above ground tank you can contact Barbara Carr. She can be reached at (312) 886-7187. You may also want to talk to Scott Hansen from the Mille Lacs Band DNR. He can be reached at (320) 532-7445.

As far as the tank removal, if you are using a Minnesota Certified contractor you are on the right track. You will need to assess the site to ensure that the tank has not leaked. At a minimum we would like a site diagram and the locations of where the samples were taken and the results. You will also need to send us a copy notification form indicating that the tanks were removed, a copy of the State's notification will be sufficient. If possible we would like to have Scott observe the removal.

I will have to get back if we need more information. If you have any additional questions please feel free to contact me.

Thanks.

Mark Restaino

Underground Storage Tanks Section

Land and Chemicals Division

U.S. EPA Region 5

77 W. Jackson Blvd. (LR-8J)

Chicago, IL 60604

Phone: (312) 886-0394

Fax: (312) 582-5872